








Design pressuer(MPa)	3.0
Testing pressuer(MPa)	4.5
Design Temperature(°C)	-196~+200°C
Volume(L)	Q1Q2side:1.400 ;Q3Q4side:1.350
Heat transfer area(m²)	1.458
Weight(kg)	8.02
Customer Part No.	
Label Code	

Model		Total plates		Q1Q2Q3Q4 (R1)		
ATS-027-40-3. 0-H(MB30-40H)		56				
	SIGNATURE	DATE	MATERIAL	SIZE	SCALE	View
DESIGNER	XLL	2025-09-25	SUS 316L	A4	1 : 1	 
CHECKER						
AUDITOR			(Title) Braze Plate Heat Exchanger			
TECHNICS						
TANDARDIZATION			(Drawing No.) T001268-013		 ATS ایکس پی اے سٹریس	
APPROVE						
(Model)	ATS-027		PAGE 1 PAGES 1			