








Note:
This product is designed, produced and inspected
in accordance with the standard of "Plate Heat
Exchanger for Refrigeration JB8701"

Design pressuer(MPa)	4.5
Testing pressuer(MPa)	6.75
Design Temperature(°C)	-196~+225°C
Volume(L)	Q1Q2side:2.892 ;Q3Q4side:2.651
Heat transfer area(m²)	2.64
Weight(kg)	16.65
Customer Part No.	
Label Code	



Model		Total plates				
ATS-120T-24-3. 0-H		24				
	SIGNATURE	DATE	MATERIAL	SIZE	SCALE	View
DESIGNER	YTL	2024-9-15	SUS 316L	A4	1 : 1	 
CHECKER			(Title) Brazed Plate Heat Exchanger			
AUDITOR						
TECHNICS						
TANDARDIZATION			(Drawing No.) T10017-012		 آ. ت. س اتحاد المهندسين	
APPROVE						
(Model)	ATS-120T		PAGE 1 PAGES 1			